


NPS Wildfire Risk Assessments Assessment Locations

National Park Service
U.S. Department of the Interior



Apostle Island National Park Overview



Basswood Island
APIS - Apostle Islands National Lakeshore

National Park Service
U.S. Department of the Interior



Rating

Facility

 High

Map Label	FMSS ID	Common Name
37	109752	BAV01 Campground Vault (Dock and Group Site)



Author: sszturm
9/6/2023 8:38 AM



NPS Wildfire Risk Assessments
NPS Fire GIS
June 2023
Data Sources: ESRI Basedata, NPS
NPS Wildfire Risk Assessment Project



NPS Wildland Fire Risk Assessment - Facility Assessment

For more information visit <https://wildfire-risk-assessments-nifc.hub.arcgis.com/>

Facility Name: BAV01 Campground Vault (Dock and Group Site)

Unit - Location: APIS - Basswood Island

FMSS ID: 109752, **Local ID:**

Structure Type, Use: Toilet, Public

Owner: National Park Service

Field Crew, Visit Date: Castillo , June 27, 2023

Coordinates (DDM): 46° 50.996' N 90° 45.385' W

Rating: High

ProtectionLevel: Not Designated,

Resources of Concern: Unknown

Occupied: No

In Community: No,

Revisit Interval: 5 yrs

Map Label: 37

Primary Access: Boat

Ingress Egress: N/A, access by foot, boat, or air only

Access Width: N/A, access by foot, boat, or air only

Access Condition: N/A, access by foot, boat, or air only

Bridge Condition: N/A, access by foot, boat, or air only

Access and Turnarounds: N/A, access by foot, boat, or air only

Facility Number or Sign: None or not clearly visible

Fuel Type: Shrub or timber

Fuel Load: Moderate

Defensible Space: Less than 30 ft treated

Topography: Slope Less than 5%

Roof Material: Noncombustible or not applicable

Siding Material: Vinyl

Foundation: Closed, Less than 6in masonry exposed

Firewood: None

Water Supply: Limited or dependent on electricity

Propane: None

Overhead Hazards: No overhead hazards

Comments:

