

Cesar E. Chavez National Monument

CECH - Cesar E. Chavez National Monument

National Park Service
U.S. Department of the Interior



Map Label	FMSS ID	Common Name
1	244591	César Chavez Home
3	NA	Chavez Burial Site
2	244590	CECH 401 Visitor Center



Rating

Rating

 Low



Author: sszturm
4/23/2024 8:00 AM

0 500 1,000 1,500 Feet

Scale: 1:6,000

NPS Wildfire Risk Assessments
NPS Fire GIS
April 2024
Data Sources: ESRI Basedata, NPS
NPS Wildfire Risk Assessment Project



NPS Wildland Fire Risk Assessment - Facility Assessment

For more information visit <https://wildfire-risk-assessments-nifc.hub.arcgis.com/>

Facility Name: Chavez Burial Site

Unit - Location: CECH - Cesar Chavez National Monument

FMSS ID: NA, **Local ID:**

Structure Type, Use: Cultural Resource, Not a building

Owner: National Park Service

Field Crew, Visit Date: Spencer Szturm, April 8, 2024

Coordinates (DDM): 35° 13.452' N 118° 33.528' W

Rating: Low

ProtectionLevel: Not Designated,

Resources of Concern: Unknown

Occupied: No

In Community: No,

Revisit Interval: 5 yrs

Map Label: 3

Primary Access: Road

Ingress Egress: 1 road in/out

Access Width: 2 lanes (Greater than 24')

Access Condition: Surfaced-paved, gradeLess than 5%

Bridge Condition: Less than 300 ft with turnaround

Access and Turnarounds: Less than 300 ft with turnaround

Facility Number or Sign: Marked and clearly visible

Fuel Type: Grass/tundra,northern hardwood litter

Fuel Load: Light or no wildland fuels

Defensible Space: 100 ft treated

Topography: Slope 5% to 20%

Roof Material: Noncombustible or not applicable

Siding Material: Not applicable

Foundation: Closed, Greater than 30in masonry exposed or N/A


Firewood: None

Water Supply: Pressurized hydrant(s) or fixed sprinkler system

Propane: None

Overhead Hazards: Overhead hazards will limit aircraft

Comments:





NPS Wildland Fire Risk Assessment - Facility Assessment

For more information visit <https://wildfire-risk-assessments-nifc.hub.arcgis.com/>

Facility Name: CECH 401 Visitor Center

Unit - Location: CECH - Ceasar Chavez National Monument

FMSS ID: 244590, **Local ID:**

Structure Type, Use: Building, Administrative

Owner: National Park Service

Field Crew, Visit Date: Spencer Szturm, April 8, 2024

Coordinates (DDM): 35° 13.440' N 118° 33.552' W

Rating: Low

ProtectionLevel: Not Designated,

Resources of Concern: Unknown

Occupied: Yes

In Community: No,

Revisit Interval: 5 yrs

Map Label: 2

Primary Access: Road

Ingress Egress: 1 road in/out

Access Width: 2 lanes (Greater than 24')

Access Condition: Surfaced-paved, gradeLess than 5%

Bridge Condition: Less than 300 ft with turnaround

Access and Turnarounds: Less than 300 ft with turnaround

Facility Number or Sign: Marked and clearly visible

Fuel Type: Grass/tundra,northern hardwood litter

Fuel Load: Light or no wildland fuels

Defensible Space: 100 ft treated

Topography: Slope 5% to 20%

Roof Material: Fire resistant- tar,rubberized

Siding Material: Wood or open sided

Foundation: Closed, Greater than 30in masonry exposed or N/A

Firewood: None

Water Supply: Pressurized hydrant(s) or fixed sprinkler system

Propane: Present and fuels clearance

Overhead Hazards: Overhead hazards will limit aircraft

Comments:





NPS Wildland Fire Risk Assessment - Facility Assessment

For more information visit <https://wildfire-risk-assessments-nifc.hub.arcgis.com/>

Facility Name: César Chavez Home

Unit - Location: CECH - Ceasar Chavez National Monument

FMSS ID: 244591, **Local ID:**

Structure Type, Use: Building, Administrative

Owner: National Park Service

Field Crew, Visit Date: Spencer Szturm, April 8, 2024

Coordinates (DDM): 35° 13.524' N 118° 33.576' W

Rating: Low

ProtectionLevel: Not Designated,

Resources of Concern: Unknown

Occupied: Yes

In Community: No,

Revisit Interval: 5 yrs

Map Label: 1

Primary Access: Road

Ingress Egress: 1 road in/out

Access Width: 2 lanes (Greater than 24')

Access Condition: Surfaced-paved, gradeLess than 5%

Bridge Condition: Less than 300 ft with turnaround

Access and Turnarounds: Less than 300 ft with turnaround

Facility Number or Sign: Marked and clearly visible

Fuel Type: Grass/tundra,northern hardwood litter

Fuel Load: Light or no wildland fuels

Defensible Space: Greater than 100ft treated

Topography: Slope 5% to 20%

Roof Material: Fire resistant- tar,rubberized

Siding Material: Wood or open sided

Foundation: Closed, Less than 6in masonry exposed

Firewood: 5ft to 30ft from facility

Water Supply: Pressurized hydrant(s) or fixed sprinkler system

Propane: Present and fuels clearance

Overhead Hazards: Overhead hazards will limit aircraft

Comments:

